



KARTHIKEYA ASSOCIATES

STRUCTURAL STABILITY CERTIFICATE OF SCHOOL BUILDING OF KENDRIYA VIDYALAYA NO.1 UPPAL, HYDERABAD

Dt: 03-05-2021


Ref: Lr No 1: F. No 1-16/KVNo.1 (U)/ 2020-21/482 Dated: 01/03/2021

As per the above Reference and the Telephonic Conversation with The Principal of Kendriya Vidyalaya No.1 School at Uppal Hyderabad to inspect and certify the Structural Stability of the Kendriya Vidyalaya No.1 School building at Hyderabad

I have thoroughly inspected the School building (Main Block, Mid Block, Primary block and also laboratory Block) on 03rd May 2021. The inspection was conducted in the presence of the Principal Mr P. Srinivasa Raju. The structure is a load bearing stone masonry structure with the proper pointing and found that no adverse indications about the structural weakness or impairment in the buildings.

Regular Maintenance is required to drain out the Rain water from chajjas, slabs and toilet blocks.

This certificate is invalid, if any subsequent modifications are made to the structure without consulting structural engineer in any manner therefore hereby certify that the said Building is structurally safe as on date.


03/05/21
N. HIMAVANTHA MAHA RAJU
M.E. (Structures)
STRUCTURAL ENGINEER
Licence No. 238/Sr/Engineer/TP10/GHMC/C/2008
Approved Valuer 2014/F-24530
Karthikeya Associates